



TECHNICKÁ INŠPEKCIA, a.s.
SLOVENSKÁ REPUBLIKA



EU – TYPE EXAMINATION CERTIFICATE – AMENDMENT 1
PRODUCTION TYPE
no.: 2311/1/2017

Notified body	Technická inšpekcia, a. s. Trnavská cesta 56, 821 01 Bratislava, Slovakia Identification number: 1354
Name of pressure equipment	Control valve for portable CO ₂ fire extinguisher (operating pressure 60 bar; material: copper alloy)
Identification of modification:	Change of burst disc – new burst disc has increased burst pressure of 250 bar (originally it was 200 bar)
Type designation:	GTV200-15/00
Applied rules and standards:	EN 3-7:2004 + A1:2007 Clause 10.6 & Annex F; EN 3-9:2006 Clause 5.4
Drawing no.:	GTV200-15/00
Manufacturer:	GÜNEŞ GAZ ARMATÜRLERİ SAN. VE TİCARET, LTD. ŞTİ., Orhanlı Merkez Mah. Anıt Sok. No: 16, Tuzla – Istanbul / Turkey
Amendment issued on the basis of requirements:	Module B according to the European Directive 2014/68/EU on pressure equipment.
Inspection Report:	4452/3/2016 and 2311/1/2017
Conclusions of examination:	Type of pressure equipment fulfils essential safety requirements according to the European Directive 2014/68/EU on pressure equipment.
Conditions of validity:	The manufacturer shall inform Technická inšpekcia, a. s. of every modification to the pressure equipment that may affect its conformity.

This AMENDMENT 1 amends EU TYPE-EXAMINATION CERTIFICATE no. 4452/3/2016.

Bratislava, 7th September 2017

The amendment is valid until: 29th December 2026




Ing. Dušan Perniš
General Director

333278

CT1-114 Aj